



**Newson
Gale**

Leading the way in hazardous area static control

Newson Gale Ltd
Omega House
Private Road 8
Colwick, Nottingham
NG4 2JX, England

Tel: +44 (0)115 940 7500
www.newson-gale.com
e-mail: groundit@newson-gale.co.uk

Declaration of Conformity

In accordance with ISO/IEC 17050: 2004

Product Approval Coding



II 2 GD T6

We, Newson Gale Ltd of Omega House, Private Road 8, Colwick, Nottingham

Declare that: The Newson Gale CAT 2 Static Grounding Reels: REEL20, REEL30, REEL50, REEL20SS, REEL30SS, REEL50SS, REEL75, VESM19, M20, M21, M33, M34 and CRSC are in accordance with the following directives:

94/9/EC ATEX Directive and its amending directives

- Have been designed and manufactured to the following specifications:

EN13463-1: 2001

Note: These have been checked against the latest standards (Technical Knowledge) and the requirements have been found to be no more onerous.

In accordance with the requirements for CAT2 non-electrical equipment a Technical file has been produced and this is stored by CSA Group Sira. Technical File Storage Ref Sira 03XT268.

I hereby declare that the equipment named above have been designed to comply with the relevant sections of the above referenced specifications. The equipment complies with the essential requirements of the Directives.

Signed by:

Name: Ian J Edge

Position: Technical Manager

Location: Colwick, Nottingham

Date: 3 August 2015

With regard to the relevant Essential Health & Safety Requirements (EHSRs) of the ATEX Directive 94/9/EC, the following declarations are made with respect to the Newson Gale Static Grounding Cable Reels

EHSR 1.1.2:

The constructional materials of the equipment are deemed to be suitable for the intended use. The reels are designed for dissipating undesirable static electricity away from conductive objects during a process. All Grounding Reels should be connected to a high reliability ground point. The Reel should be operated carefully, slowly and smoothly. The Reel should be taken out of service if it becomes damaged. The reel should be returned to Newson Gale Ltd for any repairs.

If you require a translation of this document please contact Newson Gale. Si vous avez besoin d'une traduction de cette page alors demandez Newson Gale. Bitten Sie Newson Gale um eine Übersetzung dieses Dokuments. Per una traduzione di questo documento, contatto Newson Gale. Para una traducción de este documento, contacto Newson Gale