Certificate Number BAS02ATEX2105X/9



Issued 19 April 2016 Page 1 of 3

SUPPLEMENTARY EC - TYPE EXAMINATION CERTIFICATE

2 Equipment or Protective System Intended for use in Potentially Explosive Atmospheres Directive 94/9/EC

3 Supplementary EC - Type BAS02ATEX2105X/9

Examination Certificate Number:

Equipment or Protective System:

Type BGE Break Glass Unit

5 Manufacturer:

Cooper MEDC Limited

Address: 6

1

4

Unit B, Sutton Parkway, Oddicroft Lane, Sutton-in-Ashfield, NG17 5FB

7 This supplementary certificate extends EC - Type Examination Certificate No. BAS02ATEX2105X to apply to equipment or protective systems designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

This supplementary certificate shall be held with the original certificate.

The original certificate was issued by The Electrical Equipment Certification Service, Notified Body Number 0600, which retains responsibility for its original documentation. Baseefa, Notified Body Number 1180, is responsible only for the additional work relating to this supplementary certificate and any other supplementary certificate it has issued.

Baseefa Customer Reference No. 0676

Project File No. 16/0089

This document is issued by the Company subject to its General Conditions for Certification Services accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and the Supplementary Terms and Conditions accessible at http://www.baseefa.com/terms-and-conditions.asp. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane, Buxton, Derbyshire SK17 9RZ Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601 e-mail info@baseefa.com web site www.baseefa.com Registered in England No. 4305578.

GENERAL MANAGER On behalf of SGS Baseefa Limited

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

Issued 19 April 2016 Page 2 of 3

13

Schedule

14

Certificate Number BAS02ATEX2105X/9

15 Description of the variation to the Equipment or Protective System

Variation 9.1

To permit an alternative actuator assembly on the break glass unit only, and clarification of labelling.

The full lists of codes are listed below.

BGE Units Switches only

(Ex) II 2 GD Ex d e IIC T6 Gb (T_{amb} - 40°C to + 70°C) Ex tb IIIC T85°C Db IP66/IP67 (T_{amb} - 40°C to + 70°C)

BGE Units with LEDs

(Ex) II 2 GD Ex d e mb IIC T6 Gb (T_{amb} - 35°C to + 70°C) Ex tb IIIC T85°C Db IP66/IP67 (T_{amb} - 35°C to + 70°C)

BGE Units with resistors

 $\langle \text{Ex} \rangle$ II 2 GD Ex d e mb IIC T4 Gb (T_{amb} - 40°C to + 70°C) Ex tb IIIC T135°C Db IP66/IP67 (T_{amb} - 40°C to + 70°C)

BGE Units with LEDs and resistors

(x) II 2 GD Ex d e mb IIC T4 Gb (T_{amb} - 35°C to + 70°C) Ex tb IIIC T135°C Db IP66/IP67 (T_{amb} - 35°C to + 70°C)

PBE Units Switches only

(Ex) II 2 GD Ex d e IIC T6 Gb (T_{amb} - 40°C to + 70°C) Ex tb IIIC T85°C Db IP66/IP67 (T_{amb} - 40°C to + 70°C)

PBE Units with LEDs

 $\langle Ex \rangle$ II 2 GD Ex d e mb IIC T6 Gb (T_{amb} - 35°C to + 70°C) Ex tb IIIC T85°C Db IP66/IP67 (T_{amb} - 35°C to + 70°C)

PBE Units with resistors

 $\langle x \rangle$ II 2 GD Ex d e mb IIC T4 Gb (T_{amb} - 40°C to + 70°C) Ex tb IIIC T135°C Db IP66/IP67 (T_{amb} - 40°C to + 70°C)

PBE Units with LEDs and resistors

(x) II 2 GD Ex d e mb IIC T4 Gb (T_{amb} - 35°C to + 70°C) Ex tb IIIC T135°C Db IP66/IP67 (T_{amb} - 35°C to + 70°C)

16 Report Number

SGS Baseefa certification report 16(C)0089.

17 Specific Conditions of Use

None additional to previous.

18 Essential Health and Safety Requirements

Compliance with the Essential Health and Safety Requirements is not affected by this variation.

Certificate Number BAS02ATEX2105X/9



Issued 19 April 2016 Page 3 of 3

19 Drawings and Documents				
Number	Sheet	Issue	Date	Description
280-656	1&2	G	18.02.16	General Assembly - BGE Unit
380-449	1	E	10.03.16	Certification Label - PBE Unit
280-659	1	E	10.03.16	Certification Label - BGE Unit